



# Briya PCS (Adams Morgan) - Lead in Water Test Results



## FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation											
Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Filter Test ID	FT Final Results - Draw A (ppb)	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right					
Briya PCS [Adams Morgan]	WS-002-001	Break Room	1	In main office 109	-	-	WF-112017-002001-01	4/6/18	FT-FY18-112017-002001	<1	<1
Briya PCS [Adams Morgan]	WS-002-003	Classroom Faucet	1	In classroom 108	-	Right	WF-112017-002003-01	4/6/18	FT-FY18-112017-002003	1.1	<1
Briya PCS [Adams Morgan]	WS-002-004	Classroom Faucet	1	In toddler classroom	-	-	WF-112017-002004-01	4/6/18	FT-FY18-112017-002004	<1	<1

Greater than 5 ppb - Devices Requiring Remediation											
Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Filter Test ID	FT Final Results - Draw A (ppb)	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right					
Briya PCS [Adams Morgan]	WS-002-002	Classroom Faucet	1	In classroom 108	-	Left	WF-112017-002002-01	4/6/18	FT-FY18-112017-002002	99.0	<1