



# Briya (Petworth) - Lead in Water Test Results



## FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation											
Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Filter Test ID	FT Final Results - Draw A (ppb)	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right					
Briya PCS [Petworth]	WS-019-001	Cooler	1	In hallway adjacent to room 90	Low	Left	WF-102017-019001-01	3/27/18	FT-FY18-102017-019001	<1	<1
Briya PCS [Petworth]	WS-019-002	Cooler	1	In hallway adjacent to room 90	High	Right	WF-102017-019002-01	3/27/18	FT-FY18-102017-019002	<1	<1
Briya PCS [Petworth]	WS-019-003	Classroom Faucet	1	In classroom 84	-	-	WF-112017-019003-01	3/27/18	FT-FY18-112017-019003	<1	<1
Briya PCS [Petworth]	WS-019-004	Classroom Faucet	1	In classroom 78	-	-	WF-112017-019004-01	3/27/18	FT-FY18-112017-019004	<1	<1
Briya PCS [Petworth]	WS-019-005	Classroom Faucet	1	In classroom 72	-	-	WF-112017-019005-01	3/27/18	FT-FY18-112017-019005	<1	<1
Briya PCS [Petworth]	WS-019-006	Break Room	1	In hallway across from room 78	-	-	WF-112017-019006-01	3/27/18	FT-FY18-112017-019006	<1	<1