



Briya PCS (Fort Totten) - Lead in Water Test Results



FY20 Filter Test

Less than 5 ppb - Devices Requiring No Remediation

Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Draw A Sample ID	FT Final Results - Draw A (ppb)	Draw B Sample ID	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right						
Briya PCS [Fort Totten]	WS-054-002	Classroom Faucet	1	In classroom 140			WF-072019-054002-02	10/16/2019	FT-FY20-072019-054002-A	<1	FT-FY20-072019-054002-B	<1
Briya PCS [Fort Totten]	WS-054-003	Cooler	1	In hallway across from room 140	High	Left	WF-072019-054003-02	10/16/2019	FT-FY20-072019-054003-A	<1	FT-FY20-072019-054003-B	<1
Briya PCS [Fort Totten]	WS-054-004	Bottle Filler	1	In hallway across from room 140			WF-072019-054004-02	10/16/2019	FT-FY20-072019-054004-A	<1	FT-FY20-072019-054004-B	<1
Briya PCS [Fort Totten]	WS-054-005	Cooler	1	In hallway across from room 140	Low	Right	WF-072019-054005-02	10/16/2019	FT-FY20-072019-054005-A	<1	FT-FY20-072019-054005-B	<1
Briya PCS [Fort Totten]	WS-054-006	Classroom Faucet	1	In classroom 138			WF-072019-054006-02	10/16/2019	FT-FY20-072019-054006-A	<1	FT-FY20-072019-054006-B	<1
Briya PCS [Fort Totten]	WS-054-007	Classroom Faucet	1	In classroom 134			WF-072019-054007-02	10/16/2019	FT-FY20-072019-054007-A	2	FT-FY20-072019-054007-B	<1
Briya PCS [Fort Totten]	WS-054-008	Break Room	1	In parent lounge			WF-072019-054008-02	10/16/2019	FT-FY20-072019-054008-A	<1	FT-FY20-072019-054008-B	<1
Briya PCS [Fort Totten]	WS-054-009	Break Room	1	In conference room 145			WF-072019-054009-02	10/16/2019	FT-FY20-072019-054009-A	<1	FT-FY20-072019-054009-B	<1
Briya PCS [Fort Totten]	WS-054-010	Cooler	1	In hallway across from room 152	High	Left	WF-072019-054010-02	10/16/2019	FT-FY20-072019-054010-A	<1	FT-FY20-072019-054010-B	<1
Briya PCS [Fort Totten]	WS-054-011	Bottle Filler	1	In hallway across from room 152			WF-072019-054011-02	10/16/2019	FT-FY20-072019-054011-A	<1	FT-FY20-072019-054011-B	<1
Briya PCS [Fort Totten]	WS-054-012	Cooler	1	In hallway across from room 152	Low	Right	WF-072019-054012-02	10/16/2019	FT-FY20-072019-054012-A	<1	FT-FY20-072019-054012-B	<1
Briya PCS [Fort Totten]	WS-054-013	Classroom Faucet	1	In classroom 158			WF-072019-054013-02	10/16/2019	FT-FY20-072019-054013-A	<1	FT-FY20-072019-054013-B	<1
Briya PCS [Fort Totten]	WS-054-014	Classroom Faucet	1	In classroom 160			WF-072019-054014-02	10/16/2019	FT-FY20-072019-054014-A	<1	FT-FY20-072019-054014-B	<1
Briya PCS [Fort Totten]	WS-054-015	Classroom Faucet	1	In classroom 164			WF-072019-054015-02	10/16/2019	FT-FY20-072019-054015-A	<1	FT-FY20-072019-054015-B	<1

Greater than 5 ppb - Devices Requiring Remediation

Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Draw A Sample ID	FT Final Results - Draw A (ppb)	Draw B Sample ID	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right						
Briya PCS [Fort Totten]	WS-054-001	Classroom Faucet	1	In classroom 142			WF-072019-054001-02	10/16/2019	FT-FY20-072019-054001-A	35	FT-FY20-072019-054001-B	1.1

*** Classroom 142 that WS-054-001 is in is no longer an ECE classroom. It is now a storage room. The filter will be removed, appropriate do not drink infographics will be applied, and it will be considered a non-consumable device. There is no need to retest this device.